

中国民用航空总局  
General Administration of Civil Aviation of China

民用机场专用设备  
使用许可证  
AIRPORT EQUIPMENT CERTIFICATE

证书编号/Certificate No.: 08404819

有效期至/Expiration Date: 2016-02-28

根据民航总局审核批准, 下列产品符合中国民用航空规章《民用机场专用设备使用管理规定》要求, 可以在民用机场内使用:

This certificate is issued in accordance with CCAR-137CA-R2, *Regulation on the Use of Airport Equipment*, and certifies that the following equipment has been approved by the General Administration of Civil Aviation of China (CAAC) for use in airport:


隔离变压器  
Isolation Transformer

型号/Model: RST-100

制造商/Manufacturer N.V. ADB S.A.

地址/Address Leuvensesteenweg, 585, B-1930, Zaventem, Belgium

设备外观&主要性能指标/ Basic Information



额定功率 Power Rating 100W

额定电流 Current Rating 6.6/6.6A

频率 Frequency 50Hz

外封材料  
Encapsulation Material 热塑橡胶  
Thermo-plastic Elastomer

备注 Notes:

- 设备详细外观及性能指标作为本证书的一部分打印于本证书背面  
Appearance and specifications of the equipment are printed overleaf as part of this certificate
- 下列方框内的登记记录表示本证书所示内容发生了变更, 变更具体内容打印于本证书背面  
Records sealed below on the blanks indicate revisions of this certificate with explanations printed overleaf

|  |  |  |  |  |
|--|--|--|--|--|
|  |  |  |  |  |
|--|--|--|--|--|


颁发日期:  
Issue Date:

2008-02-29





Outline dimensions



Nominal length of primary leads: 60 cm  
Nominal length of secondary lead: 120 cm

尺寸 Dimensions

L×W×H

125mm×115mm×90mm

最大初级电压

Max. Circuit Voltage

5000V

最大次级开路电压

Max. Secondary Circuit Voltage

37V

最小功率因数

Mix. Power Factor

0.98

效率

Efficiency

90%