

中国民用航空总局
General Administration of Civil Aviation of China

民用机场专用设备
使用许可证
AIRPORT EQUIPMENT CERTIFICATE

证书编号/Certificate No.: 08404817

有效期至/Expiration Date: 2016-02-28

根据民航总局审核批准, 下列产品符合中国民用航空规章《民用机场专用设备使用管理规定》要求, 可以在民用机场内使用:

This certificate is issued in accordance with CCAR-137CA-R2, *Regulation on the Use of Airport Equipment*, and certifies that the following equipment has been approved by the General Administration of Civil Aviation of China (CAAC) for use in airport:


隔离变压器
Isolation Transformer

型号/Model: RST-45

制造商/Manufacturer **N.V. ADB S.A.**

地址/Address **Leuvensesteenweg, 585, B-1930, Zaventem, Belgium**

设备外观&主要性能指标/ Basic Information



额定功率 Power Rating 45W

额定电流 Current Rating 6.6/6.6A

频率 Frequency 50Hz

外封材料
Encapsulation Material Thermo-plastic Elastomer

备注 Notes:

1. 设备详细外观及性能指标作为本证书的一部分打印于本证书背面
Appearance and specifications of the equipment are printed overleaf as part of this certificate
2. 下方方框内的登记记录表示本证书所示内容发生了变更, 变更具体内容打印于本证书背面
Records sealed below on the blanks indicate revisions of this certificate with explanations printed overleaf


--	--	--	--	--

颁发日期:
Issue Date:

2008-02-29



Outline dimensions



Nominal length of primary leads: 60 cm
Nominal length of secondary lead: 120 cm

尺寸 Dimensions

L×W×H

114mm×101mm×80mm

最大初级电压

Max. Circuit Voltage

5000V

最大次级开路电压

Max. Secondary Circuit Voltage

17V

最小功率因数

Mix. Power Factor

0.98

效率

Efficiency

87%